

H2 INDUSTRIAL BOILER										
Date of factsheet	18-5-2020									
Author	Loes Rutten									
Sector	Industry: Generic									
ETS / Non-ETS	ETS									
Type of Technology	Hydrogen									
Description	<p>This factsheet considers steam boilers fueled by 100% hydrogen. Hydrogen can be used as an alternative input energy carrier for boilers. To be considered as a renewable option, the hydrogen (H2) has to be produced from a renewable source, such as from electrolysis using renewable electricity.</p> <p>The combustion characteristics of hydrogen, such as velocity and flame heating properties, are different than from natural gas. The use of hydrogen in generic industrial boilers has proven feasible and only requires a retrofit of the burner to accommodate hydrogen gas properties (E4tech, 2015). Ricardo-AEA (2012) assumes that burner replacement is required to burning hydrogen at concentrations higher than 30%.</p> <p>Whereas up to a 30% blend of hydrogen with natural gas has possibly the same efficiency as natural gas, 100% hydrogen oxyfuel burners are 15 percentage points more efficient than natural gas due to flue gas condensation and recycling plus reduced volume of exhaust gas (Ricardo-AEA, 2012). Whether this includes the energy required for the production of O2 (that might be used instead of air in the combustion process) is not specified.</p>									
TRL level 2020	<p>TRL 9</p> <p>Hydrogen burners are available and sometimes used at sites with available by-product hydrogen. They are used commercially in some industrial niches, although there is currently no wider market for intentionally pure hydrogen production as fuel. (E4tech, 2015; VNP, 2018). TKI Nieuw gas (2018) estimates that H2 boilers will be ready for a wider market introduction by 2025, and ready for the mass market by 2035. Although laws and safety regulations readily exist for the use of H2 within the industry sector, regulations are currently absent for the use of H2 in adjacent sectors, which may slow down the roll-out of H2 technologies (TKI Nieuw gas, 2018).</p>									
TECHNICAL DIMENSIONS										
Capacity	Functional Unit		Value and Range							
	MWth;out		50.00							
Potential	PJ/year	NL	Current			2030			2050	
			100.00	-	101.00	100.00	-	101.00	100.00	-
Market share	%		-			0.01			0.02	
			-	-	-	0.01	-	0.03	0.02	-
Capacity utilization factor	0.90									
Full-load running hours per year	7,900.00									
Unit of Activity	PJ/year									
Technical lifetime (years)	25.00									
Progress ratio										
Hourly profile	No									
Explanation	<p>Capacity: The typical size of a hydrogen boiler is not specified in literature. It is assumed that steam boilers of any size can be converted into a hydrogen boiler by retrofitting the burner. Therefore, the size of industrial H2 boilers can range anywhere from < 1 MWth to > 300 MWth (IEA-ETSAP, 2010; Ecodesign, 2014).</p> <p>Potential: Hydrogen boilers can be used for the same application in industry as the current gas-fired boilers. Solutions for decarbonisation in industry are also sought in electrification (Klimaatakkoord, 2018; TNO 2019; DNV GL, 2018), but H2 boilers can reach higher pressures and temperatures than electric alternatives, and therefore H2 boilers are a key to substitute the 100 PJ industrial heat demand above 250 °C, rather than the 124 PJ heat demand below 250 °C (TKI Nieuw gas, 2018). Achtergrondnotitie Klimaatakkoord (2018) yields a similar figure of 101 PJ: They describe that from the 168 PJ heat demand of the Dutch industry, 67 PJ of 142 PJ heat demand below 300 °C can be electrified by 2030. The remaining 75 PJ (<300°C) and 26 PJ (>300°C), which is 60% of the industrial heat demand, is interpreted as potential market for Hydrogen boilers in this factsheet.</p> <p>Market share: E4tech (2015) studies two scenarios for the UK with targeted H2 deployment (critical path) and widespread H2 deployment (full contribution) and finds that hydrogen may account for up to 50% of the industrial fuel use for high- and low-temperature heat in industry in 2050. These figures are under the assumption that sufficient hydrogen is available to fuel the hydrogen boiler.</p> <p>Running hours: It is assumed a hydrogen boiler can run 90% of the time (E4tech, 2015). Rounded off, this implies ~7900 running hours.</p> <p>Lifetime: The technical lifetime according to literature varies from 20 years (VNP, 2018; Ricardo-AEA, 2012) to 25 years (E4tech, 2015).</p>									
COSTS										
Year of Euro	2015									
Investment costs	Euro per Functional Unit		Current			2030			2050	
	mIn. € / MWth;out		121.69	-	250.00	121.69	-	121.69	22.83	-
Other costs per year	mIn. € / MWth;out		-			-			-	
			Min	-	Max	Min	-	Max	Min	-
Fixed operational costs per year (excl. fuel costs)	mIn. € / MWth;out		3.96			4.33			4.33	
			3.96	-	3.96	4.33	-	4.33	4.33	-
Variable costs per year	mIn. € / MWth;out		-			-			-	
			Min	-	Max	Min	-	Max	Min	-
Costs explanation	<p>Investment costs: There is only limited information available on the cost of hydrogen boilers. According to E4tech (2015) and VNP (2018) only retrofitting of the burners of existing boilers is required. E4tech provides a CAPEX of 98.3 GBP/kW for a low temperature heat* and drying 100% hydrogen boiler.</p> <p>In VNP (2018), Lux Research estimates 250 EUR/kW steam output for only retrofitting an existing 15MW boiler with a hydrogen burner.</p> <p>Ricardo-AEA (2012) assumes that 30% blended hydrogen with natural gas has no increase in capital costs compared to a fossil equivalent, whereas 100% hydrogen with oxyburner would incur a 30% increased capital cost to pay for condensation and flue gas recycle. Representative data for a natural gas boiler can be found in the factsheet on the industrial gas boiler (to be published). In that case, a non-conservative scenario for 2050 leads to an investment cost of 23E/kW for boilers burning 100% hydrogen, when these won't be available solely as a retrofit, but as a standard technology option for new boilers (TNO, 2020).</p> <p>Operational costs: The current OPEX is 3.2 EUR2018/kW per year and expected to go up to 4 EUR2018/kW by 2030 according to E4tech (2015). If OPEX follows the expert predictions that H2 boiler costs will approximate regular gas-fired boilers, the OPEX may reduce to 2,8 to 0,4 EUR/kW (EnergyMatters, 2015; Ecodesign, 2014).</p> <p>In their analysis, Ricardo-AEA (2012) make the assumption that operating costs have no net increase over their fossil equivalents, because ongoing energy costs are much more important for full lifecycle costs.</p> <p>* 'low temperature' refers to the definition of the UK Department of Energy and Climate Change, specifying high temperatures as above 1000°C (production of glass, cement, iron and steel), and low temperature process heat as 300-500°C (food and drink, chemicals and pulp and paper industry).</p>									
ENERGY IN- AND OUTPUTS										
Energy carriers (per unit of main output)	Main output: Steam	PJ	Current			2030			2050	
			-1.00	-	-1.00	-1.00	-	-1.00	-1.00	-
	Hydrogen	PJ	1.00			1.00			1.00	
			1.00	-	1.11	1.00	-	1.11	1.00	-
		PJ	-			-			-	
			Min	-	Max	Min	-	Max	Min	-
	PJ	-			-			-		
		Min	-	Max	Min	-	Max	Min	-	Max
Energy in- and Outputs explanation	<p>The energy efficiency is 85% based on HHV according to VNP (2018). This corresponds to an efficiency of 100% based on LHV, assuming a HHV energy content of 12,7 MJ/m3 (Bossel & Elisasson, 2002) and a LHV energy content of 10,8 (RVO, 2018). E4tech (2015) reports an efficiency of 90% but does not specify whether this is based on LHV or HHV. Ricardo-AEA (2012) reports an efficiency of 100%, LHV or HHV not specified.</p>									

MATERIAL FLOWS (OPTIONAL)											
Material flows	Material	Unit	Current			2030			2050		
			-	-	-	-	-	-	-	-	-
			Min	-	Max	Min	-	Max	Min	-	Max
Material flows explanation											
EMISSIONS (Non-fuel/energy-related emissions or emissions reductions (e.g. CCS))											
Emissions	Substance	Unit	Current			2030			2050		
			-	-	-	-	-	-	-	-	-
			Min	-	Max	Min	-	Max	Min	-	Max
			-	-	-	-	-	-	-	-	-
			Min	-	Max	Min	-	Max	Min	-	Max
<p>According to Ilbas et al. (2005), hydrogen can be a very clean alternative to fossil fuels, as there are no CO, CO₂, SO_x and unburned hydrocarbons emissions from the hydrogen fuel combustion. The only pollutant from the hydrogen combustion is NO_x. In their study on NO_x formation in hydrogen combustion, high NO_x levels were found at high temperature regions and low NO_x levels at low temperature regions. For 100% H₂, they predicted maximum NO_x level as 1961 ppm at the maximum temperature of 2325 K. The predicted average NO_x level at the combustor exit was 537 ppm at a temperature of 1372 K. The overall reduction in NO emissions was about 20% using 25% air staging compared with the NO emission from the non-staged hydrogen combustion. Mixing hydrogen with natural gas decreases the flame temperature, and thereby the NO_x formation. Johansson (2005) also notes that according to literature, the NO_x emission can be resolved by increasing the excess of air, resulting in a lower burning temperature.</p> <p>The allowed emission of hydrogen boilers is not specified in the Dutch regulation 'Besluit activiteiten leefomgeving' (2020). In article 4.4311 of this regulation, the nitrogen oxides emission boundary value other types of >400 kW boilers is defined between 70 mg/Nm³ (natural gas) and 275 mg/Nm³ (biomass).</p>											
OTHER											
Parameter	Unit	Current			2030			2050			
		-	-	-	-	-	-	-	-		
		Min	-	Max	Min	-	Max	Min	-	Max	
Explanation											
REFERENCES AND SOURCES											
Scenarios for deployment of hydrogen in contributing to meeting carbon budgets and the 2050 target, E4tech, 2015											
Industrial combustion boilers, IEA-ETSAP, 2010											
Hydrogen as fuel for turbines and engines, K. Johansson, 2005											
Contouren van een Routekaart Waterstof, TKI Nieuw Gas Topsector Energie, 2018											
Hydrogen as burner fuel: modelling of hydrogen-hydrocarbon composite fuel combustion and NO _x formation in a small burner, Ilbas et al., 2005											
Energy and The Hydrogen Economy, Bossel, Ulf & Eliasson, Baldur, 2003											
Eindverslag Haalbaarheidsstudie Elektrificatie bestaande gasketels, ECN part of TNO, 2019											
Decarbonising the steam supply of the Dutch paper and board industry, VNP, 2018											
Electrification of industry: Facilitating the integration of offshore wind with power-to-heat in industry, DNV GL, 2018											
Contouren van een Routekaart Waterstof, TKI Nieuw Gas Topsector Energie, 2018											
E4tech & Energy, Development of water electrolysis in the European Union, 2014											
Klimaatakkoord achtergrondnotitie: De potentie van Power to Heat in de Nederlandse Industrie, 2018											
Steam Handbook: an introduction to steam generation and distribution, Endress+Hauser, 2017											
The Future of Heating: A strategic framework for low carbon heat in the UK, Department of Energy and Climate Change, 2012											
The Netherlands: list of fuels and standard CO ₂ emission factors, RVO, 2018											
Flexibilisering industriële WKK, EnergyMatters, 2015											
Dutch program for the acceleration of sustainable heat management in industry, ECN, 2017											
Ecodesign Preparatory Study on Steam Boilers, PwC, Fraunhofer ISI and ICCS-NTUA, 2014											
Besluit Activiteiten Leefomgeving, 2020											
www.cleanboiler.org: boiler efficiency improvement - boiler-combustion, consulted 14/05/2020											
TNO, internal consultation. 2020.											