

HEAT PUMP - AIR TO WATER

| | |
|-------------------|-------------------------------|
| Date of factsheet | 16-12-2020 |
| Author | Jeffrey Sipma |
| Sector | Trade, services and utilities |


| | |
|---------------|---------|
| ETS / Non-ETS | Non-ETS |
|---------------|---------|

| | |
|--------------------|--------------------|
| Type of Technology | Emission reduction |
|--------------------|--------------------|

Description

Air to water heat pumps
 This type of heat pump extracts heat from the outside air. The transport medium for heat inside the dwelling is water, hence the names 'air-to-water heat pump'.

Figure 1 illustrates the configurations for this type of heat pump.



(Source: PrinceEnergy, 2021)

1. Air is drawn into the heat pump from the outside air.
2. The heat pump absorbs the heat from the air and transfers this heat via a refrigerant to the water system in the building, providing heating and hot tap water.
3. The heated water from the heat pump is circulated around the heating circuit and indirectly passed through an hot water cylinder via a coil, just as it would be with a traditional boiler system. A complementary options could be an integrated or separated (electric) boiler for additional hot tap water usage.
4. Hot water is stored within this cylinder and is available as hot tap water.
5. The heated water from the heat pump radiates heat through either radiators or more suitably through under floor heating and is then circulated back through the pump to be re-heated.

A heating device must, among other things, be selected for its heating capacity. This capacity depends on (1) the degree of insulation of a building, (2) the desired interior temperature and (3) the size of the building. The largest houses are larger than the smallest buildings within the utility sector (and the other way around). This means that every heat pump that is placed in the residential sector, can also be found within the services sector. Within the latter sector however, there are also much larger buildings; this does create a different situation with a much larger heat demand. Such buildings are often equipped with several heating appliances, which are placed in a cascade arrangement. When the outside temperature drops further, an additional appliance will start operating. This way, electrical heat pumps are most often combined with gas fired boilers. The more efficient, but more expensive heat pump, for example, provides 80% of the heat demand, the gas boiler only assists on the coldest days in order to meet the "peak heat demand". The combination of an electric heat pumps with a gas fired boilers can be considered as a 'hybrid cascade setup'. In a services building that reaches the level of 'nearly zero energy', a stand-alone heat pump could be sufficient, just as in a residential building.

| | |
|----------------|------------------------|
| TRL level 2020 | TRL 9 |
| | Commercial technology. |

TECHNICAL DIMENSIONS

| Capacity | Functional Unit | | Value and Range | | | | | |
|----------------------------------|-----------------|----|-----------------|---|------|-----|------|----------|
| | kWth | | 770 - 443 | | | | | |
| Potential | | | Current | | 2030 | | 2050 | |
| Market share | % | NL | Min | - | Max | Min | - | Max |
| Capacity utilization factor | NA | | 0.01 | - | 0.01 | Min | - | Max |
| Full-load running hours per year | 961-1765 | | | | | | | |
| Unit of Activity | GJ/year | | | | | | | 2,975.97 |
| Technical lifetime (years) | 15-20 | | | | | | | |
| Progress ratio | | | | | | | | - |
| Hourly profile | Yes | | | | | | | |

Explanation

Source for data: for the services sector, TNO Energy Transition Studies, often use the investment costs of Arcadis (2020). In order to calculate investments costs per m2 floor area, or per kWth, Arcadis distinguishes nine different building types as offices, schools, hospitals, etc. Within these types, three different building sizes have been distinguished. As well an assumption for the insulation level is used, related to new- and existing buildings. This together, determines the heat demand and therefore the needed capacity and investment costs in each situation.

Table 1 shows the typical needed heating capacity by building type and building size for new buildings.

| Building type | Heating demand (W/m2) | building size (m2) | | | | heating capacity needed (kWth) | | | |
|---|-----------------------|--------------------|--------------|---------------|--------------|--------------------------------|------------|------------|------------|
| | | small | medium | large | average | small | medium | large | average |
| Healthcare with beds; as hospital, nursing home | 65 | na | 5.705 | 34.178 | 19.942 | na | 370 | 2.219 | 1.295 |
| Healthcare centre without beds | 65 | 877 | na | na | 877 | 57 | na | na | 57 |
| Education (school) | 58 | 2.022 | 7.610 | 15.729 | 8.454 | 118 | 445 | 919 | 494 |
| Public buildings as theatre, museum | 52 | 1.745 | 4.964 | 9.707 | 5.472 | 91 | 258 | 504 | 284 |
| Office | 52 | 1.681 | 4.383 | 24.553 | 10.206 | 87 | 228 | 1.275 | 530 |
| Lodging, as hotel | 52 | na | 3.678 | na | 3.678 | na | 191 | na | 191 |
| Prison | 45 | na | 15.854 | na | 15.854 | na | 721 | na | 721 |
| Sport hall | 45 | 158 | 2.910 | 8.468 | 3.845 | 7 | 132 | 385 | 175 |
| Shop | 32 | 158 | 1.460 | 20.907 | 7.508 | 5 | 47 | 679 | 244 |
| Average | 52 | 1.107 | 5.821 | 18.924 | 8.426 | 61 | 299 | 997 | 443 |

(Source: Own elaboration based on Arcadis, 2020)

Table 2 shows the same for existing buildings.

| Building type | Heating demand (W/m ²) | building size (m ²) | | | | heating capacity needed (kWth) | | | |
|---|------------------------------------|---------------------------------|--------------|---------------|--------------|--------------------------------|------------|--------------|------------|
| | | small | medium | large | average | small | medium | large | average |
| Healthcare with beds; as hospital, nursing home | 100 | 1.850 | 4.200 | 15.950 | 7.333 | 185 | 420 | 1.595 | 733 |
| Healthcare centre without beds | 100 | 600 | 2.850 | 5.450 | 2.967 | 60 | 285 | 545 | 297 |
| Education (school) | 90 | 1.800 | 12.500 | 29.950 | 14.750 | 162 | 1.125 | 2.696 | 1.328 |
| Public buildings as theatre, museum | 80 | 1.150 | 4.350 | 11.400 | 5.633 | 92 | 348 | 912 | 451 |
| Office | 80 | 1.200 | 5.300 | 17.450 | 7.983 | 96 | 424 | 1.396 | 639 |
| Lodging, as hotel | 80 | 2.050 | 4.400 | 70.800 | 25.750 | 164 | 352 | 5.664 | 2.060 |
| Prison | 70 | 6.000 | 17.600 | 27.600 | 17.067 | 420 | 1.232 | 1.932 | 1.195 |
| Sport hall | 70 | 450 | 2.200 | 4.550 | 2.400 | 32 | 154 | 319 | 168 |
| Shop | 50 | 200 | 850 | 2.800 | 1.283 | 10 | 43 | 140 | 64 |
| Average | 80 | 1.700 | 6.028 | 20.661 | 9.463 | 136 | 487 | 1.689 | 770 |

(Source: Own elaboration based on Arcadis, 2020)

The non-weighted averages mentioned in the last rows of these tables, have been entered as the final capacity range of this Factsheet: [existing buildings with often a cascade configuration - new buildings with a stand-alone heat pump]. The weighted averages would be much smaller since there are many more smaller buildings than there are larger ones. Note the differences in individual building sizes within one table, and between the two tables that lead to a much larger range of needed capacities.

Capacity related:

Since on average the heating capacity of a heat pump within the services sector is larger compared to one in the residential sector, the installed thermal capacity is (on average) twice as large within the services sector.

Market share related:

When considering the air-, soil- and groundwater-to-water heat pumps within the services sector only, the penetration rate expressed as the installed heating capacity of the air-to-water heat pump lies around 16% (CBS, 2020). The penetration rate of electric heat pumps in general within offices with an energy label, lies at the moment around 9% (Dutch Energy Label database, 2019, edited). If we take this as a very rough estimation for the whole services sector, then the market penetration of this type of heat pump is 9%*16%=1,5%.

Running hours:

The first mentioned number represents a new building (heat pumps as a stand-alone device), the second an existing building (heat pump in a cascade configuration) (Warmtepomp-wetjes.nl, 2021).

COSTS

| Year of Euro | 2015 | | | | | | | | | | | | |
|---|--------------------------|--|--|--|---------|---|-------|------|---|-----|------|---|-----|
| Investment costs | Euro per Functional Unit | | | | Current | | | 2030 | | | 2050 | | |
| | mIn. € / kWth | | | | 1,559 | - | 1,559 | 633 | - | 633 | Min | - | Max |
| Other costs per year | mIn. € / kWth | | | | - | - | - | - | - | - | - | - | - |
| Fixed operational costs per year (excl. fuel costs) | mIn. € / kWth | | | | 40 | - | 40 | Min | - | Max | Min | - | Max |
| | mIn. € / kWth | | | | - | - | - | - | - | - | - | - | - |
| Variable costs per year | mIn. € / kWth | | | | Min | - | Max | Min | - | Max | Min | - | Max |

Costs explanation

Investment costs related:

- In this Factsheet the investment costs represent the situation whereby implementing the heat pump occurs at an 'independent moment'. Another situation, distinguished by Arcadis, and called 'a natural moment'. This would reduce the total costs since (1) there would be some mutual costs to share (among all measures taken; think of hiring a crane, for instance) and (2) the investment for new gas boilers had to be done anyway and are therefore subtracted. But, in case of implementing heat pumps, the difference is small; it would reduce the investment costs with only 2 until 7%.

- Besides the investment costs for the hardware, the costs above include as well wages, some direct costs as general execution costs and a contribution for risks.

- Costs that are not included are for example the internal costs of the project developer, subsidies, fees for the installation consultant.

- For existing buildings, additionally costs have been included to remove the 'old heating system' out of the building.

Table 3 shows Investment costs (€2015/kWth) for existing/new buildings, by building type and size, related to the previous mentioned needed heating capacity. As can be seen, not all combinations have been given investment costs by Arcadis ('na' = 'not applicable/available'). When the heat demand and the 'air-to-water' heat pump are not a logical combination ('not applicable'), then another heat pump type could have been chosen (see the other two related Factsheets). The non-weighted averages mentioned in the last rows of these tables, have been entered as the final 2020 and 2030 investment costs. For 2020 this represents the cascading configuration in existing buildings; the number at 2030 represents the equivalent for a stand-alone heat pump in a new building. Note that for all new construction, both residential and non-residential construction, permit applications from 1 January 2021 must meet the requirements for Nearly Zero-Energy Buildings (in Dutch abbreviated as 'BENG').

| Building type | Investment costs (euro/kW) Existing buildings, cascade | | | | Investment costs (euro/kW) New buildings, stand alone | | | |
|---|---|--------------|--------------|--------------|--|------------|------------|------------|
| | small | medium | large | average | small | medium | large | average |
| Healthcare with beds; as hospital, nursing home | 1.647 | 1.343 | 1.318 | 1.449 | na | 636 | 636 | 636 |
| Healthcare centre without beds | 2.700 | 1.595 | 1.343 | 1.879 | 540 | na | na | 540 |
| Education (school) | 1.219 | 1.003 | na | 1.111 | 636 | 600 | 600 | 612 |
| Public buildings as theatre, museum | 2.632 | 1.556 | 1.309 | 1.832 | 616 | 616 | 616 | 616 |
| Office | 2.632 | 1.309 | 1.285 | 1.742 | na | 636 | 616 | 626 |
| Lodging, as hotel | 1.646 | 1.556 | 1.285 | 1.495 | na | 616 | na | 616 |
| Prison | 1.481 | 1.224 | 1.224 | 1.310 | na | 590 | na | 590 |
| Sport hall | na | 1.567 | 1.481 | 1.524 | na | 613 | 590 | 602 |
| Shop | na | na | 1.688 | 1.688 | na | 858 | 858 | 858 |
| Average | 2.000 | 1.394 | 1.367 | 1.559 | 597 | 646 | 653 | 633 |

(Source: Own elaboration based on Arcadis, 2020)

Observation:

- The costs expressed as euro/kWth lie lower in 2030 compared to 2020 (new compared to existing buildings), due to the fact that less equipment is needed in 2030 (no cascading system). Note that the decrease in heating demand in 2030 counteracts this effect to a certain extent, but does not dominate the net effect (as it does with the other two heat pump types, described in the related Factsheets).

Maintenance costs related:

The estimated cost of servicing a heat pump is, among others, dependent on the heat pump type, condition, size, age, location, brand and maintenance history of the unit; therefore it's difficult to come up with an average number (CE Delft, 2021; Bloomquist, 2001).

| ENERGY IN- AND OUTPUTS | | | | | | | | | | | |
|---|--|---------|---------|-----|------|------|-----|------|------|-----|-----|
| Energy carriers (per unit of main output) | Energy carrier | Unit | Current | | | 2030 | | | 2050 | | |
| | Main output: Heat | PJ | | - | - | - | - | - | - | - | - |
| | | | Min | - | Max | Min | - | Max | Min | - | Max |
| | Ambient heat | PJ | | - | - | - | - | - | - | - | - |
| | | | Min | - | Max | Min | - | Max | Min | - | Max |
| Electricity | PJ | | - | - | - | - | - | - | - | - | |
| | | Min | - | Max | Min | - | Max | Min | - | Max | |
| | PJ | | - | - | - | - | - | - | - | - | |
| | | Min | - | Max | Min | - | Max | Min | - | Max | |
| Energy in- and Outputs explanation | <p>The efficiency of a heat pump is expressed as the Coefficient of Performance (COP). For example, a COP of 3 means that 1 unit of electricity is used to produce 3 units of heat, by using 2 units of ambient heat. The COP mainly depends on the difference between source temperature and delivery temperature. The higher the source temperature and the lower the delivery temperature the higher the COP. In winter, the temperature difference is larger, resulting in a lower COP. The annual average COP is called the seasonal coefficient of performance (SCOP), or the Seasonal Performance Factor (SPF). In a study 11 air-to-water heat pumps have been monitored, giving an average SPF of 2,8 (bouw-energie). This SPF had been converted into the 'Energy in- and Outputs' mentioned in this Factsheet (stating the usage of 'ambient heat' as -1 MJ).</p> <p>Other sources make other assumptions: -NTA 8800 (2020) is a new determination method for the energy performance of buildings in the Netherlands that will be implemented in 2020 (NTA 8800, 2018). The mean COP of an air-to-water heat pump is 2,35 - 3,15 in case of a delivery temperature of 35-40 °C. -ETRI (2014) indicates COP = 3,1 for an air-to-water heat pump in 2020, COP = 3,2 in 2030 and COP = 3,4 in 2050, in a commercial building. -CE Delft (2018) indicates the SCOP of an air-to-water heat pump is 3,5 - 4,5 in case of a delivery temperature of 35 °C. For domestic hot tap water the SCOP is 2,0 to 2,6</p> | | | | | | | | | | |
| MATERIAL FLOWS (OPTIONAL) | | | | | | | | | | | |
| Material flows | Material | Unit | Current | | | 2030 | | | 2050 | | |
| | | | | - | - | - | - | - | - | - | |
| | Min | - | Max | Min | - | Max | Min | - | Max | | |
| Material flows explanation | | | | | | | | | | | |
| EMISSIONS (Non-fuel/energy-related emissions or emissions reductions (e.g. CCS)) | | | | | | | | | | | |
| Emissions | Substance | Unit | Current | | | 2030 | | | 2050 | | |
| | | | | - | - | - | - | - | - | - | |
| | Min | - | Max | Min | - | Max | Min | - | Max | | |
| | | | | - | - | - | - | - | - | - | |
| | Min | - | Max | Min | - | Max | Min | - | Max | | |
| Emissions explanation | | | | | | | | | | | |
| OTHER | | | | | | | | | | | |
| Parameter | Unit | Current | | | 2030 | | | 2050 | | | |
| Costs insulation measures (label E or D to A or A+) | euros2015 | | - | - | - | - | - | - | - | - | |
| Costs Low temperature heating - radiators | euros2015 | | - | - | - | - | - | - | - | - | |
| Costs Low temperature heating - floor heating | euros2015 | | - | - | - | - | - | - | - | - | |
| | euros2015 | | - | - | - | - | - | - | - | - | |
| Explanation | | | | | | | | | | | |
| REFERENCES AND SOURCES | | | | | | | | | | | |
| Arcadis. (2020). Actualisatie Investeringskosten Energiebesparende Maatregelen Bestaande Utiliteitsbouw 2020. Retrieved from: not yet published | | | | | | | | | | | |
| Kampen, v. P. P. (2000). Marktanalyse en –prognose van airconditioningsystemen, Rapportage van een markt-onderzoek naar causale factoren en trends | | | | | | | | | | | |
| Schoemaker, F. S., Witkop, D., Schouten, F., & Beerenhout, M. (2020). Nationaal Warmtepomp Trendrapport 2020. | | | | | | | | | | | |
| Segers, R., & Busker, H. (2015). Equivalent full load hours for heating of reversible air-air heat pumps. | | | | | | | | | | | |
| CBS (2020) Warmtepompen; aantallen, thermisch vermogen en energiestromen | | | | | | | | | | | |
| Warmtepomp Weetjes (2021). Available at: https://warmtepomp-weetjes.nl/uitleg/warmtepomp-indicatie-etabel/ | | | | | | | | | | | |
| Bouw-energie.be (2021). Available at: https://bouw-energie.be/nl-be/blog/past/rendement-warmtepompen | | | | | | | | | | | |
| Arcadis (2018). KOSTENOPTIMALITEITSSTUDIE BENG. INVESTERINGSKOSTEN ENERGIEBESPARENDE MAATREGELEN UTILITEITSBOUW & WONINGBOUW | | | | | | | | | | | |
| NTA8800 (2020). Available at: https://www.nen.nl/media/wysiwyg/NTA_8800.pdf | | | | | | | | | | | |
| Dutch Energy Label database (2019_), edited. | | | | | | | | | | | |
| PrinceEnergy (2021). Available at: https://www.princeenergy.co.uk/services/renewables/heat-pumps/ | | | | | | | | | | | |
| ETRI (2014) https://setis.ec.europa.eu/publications/relevant-report | | | | | | | | | | | |
| CE Delft (2021). Available at: https://ce.nl/method/warmtetechnieken/ | | | | | | | | | | | |
| Bloomquist (2001). The economics of geothermal heat pump systems for commercial and institutional buildings, Proceedings Conference on geothermal energy in underground Mines, Ustron, Poland 2001. Available at: https://www.geothermal-energy.org/pdf/IGStandard/ISS/2003Germany/II/9_1_gor.pdf | | | | | | | | | | | |